



ADDENDUM NUMBER 2
Dugdale Park Renovation
Waukegan Park District #1262

DATE: November 19, 2024

TO: ALL KNOWN BID DOCUMENT RECIPIENTS

VIA EMAIL – 1 page as described below

The following changes or clarifications for the above-referenced bid shall be made part of the bidding documents and a copy of this addendum cover page shall be submitted and /or attached to the Bid Proposal Form.

1. Clarifications: Restroom Building

- a. Refer to bid proposal form for contractor purchase equipment and site furnishing items.
- b. Refer to sheet 7.0, Landscape Plan – North, for owner purchase and install items.
Refer to bid proposal form for contractor purchase landscape scope.
- c. No soil boring were completed during the planning of this project.
- d. The backstop fencing is to be black vinyl, refer to specification 32 3113 Chain Link Fence for color and material information.
- e. The ornamental fence is to be Ameristar Echelon Plus – Monarch two rail.
- f. The concrete at the splash pad is to have welded wire mesh reinforcement, no fiber reinforcement, and grounded per NEC.
- g. The radial lines shown on the splash pad concrete layout are control joint unless otherwise indicated with “EJ” symbol to note expansion joints. See sheet 3.4, Layout Plan-Baseball, Splash Pad & Shelter Enlargement for joint layout.